

ER-21. 6/1.

UT of Jammu & Kashmir

KASHMIR PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Testing Laboratory Public Health Engineering Division Sopore
Land mark: Iqbal Market Sopore.

Sample Analysed at: WTL Sopore

Date of Examination: 13-3-2021

Lab. Ref no. PHE/WTL/Spr 51

Concerned Sub Div: Sopore

Report to: Sanctorum Public School (Gallad Sopore)

REPORT

s.no	Parameters	Unit	Permissible limit	Result
1.	Iron	Mg/l	0.3-0.3	0.00
2.	Nitrate	Mg/l	10.5-45	0.00
3.	Fluorides	Mg/l	1.0-1.5	0.00
4.	Chloride	Mg/l	250-1000	80.00
5.	Bacteriological	MPN	0.00-0.00	(-ve)
6.	Residual Chlorine	Mg/l	0.2-1.0	0.1
7.	Sulphate	Mg/l	200-400	< 200
8.	Manganese	Mg/l	0.3-0.1	0.00
9.	P.H		6.5-8.5	7.5
10.	Turbidity	NTU	1.0-5.0	0.75
11.	Hardness	Mg/l	200-600	90.00
12.	Phosphate	Mg/l	1.0-1.5	0.00

13. Ammonia. mg/L. 0.5 0.00.

As per the above tested parameters there is no chemical contamination found/present in the fetched and Rott water. Hence water is fit for human consumption.

Lab Assistant

13/3/2021

self att.



Chemist

Assistant Executive Engineer
Asstt. Executive Engineer
PHE Sub Division
Sopore

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

P.H.E
No. WTL/SPT/SI

Dated: 13-3-2024

It is certified that an Inspection team headed by Hussaini Muhi-ud-din (Savit)
(Name of Officers with designation) from P.H.E. Division Sopore (WTL)
(Name of Department/ Office) inspected the Sanatorium Public School Lalad
(Name & Address of the school) on 13-3-2024 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.
The above is valid for a period of One year

[Signature]
Assistant Engineer
PHE (J.S) Sub Division

Signature with Seal: Sopore

Name : MALINA FATIMA

Designation : Assistant Engineer

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department : PHE Di- Sopore

To

.....

.....

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Tel/Fax: 01954-222256

Email: eomcsopore@gmail.com

OFFICE OF THE EXECUTIVE OFFICER
MUNICIPAL COUNCIL SOPORE

TO WHOM I MAY CONCERN

In view of the representation submitted by principal Sanctorum Higher Secondary School National High Way Lalad Sopore vide of Dated: 27-11-2019 and as reported by the Sanitary Inspector of Municipal Council Sopore, it is certified that there is no any insanitary/ hygienic of the premises of Sanctorum Higher Secondary School National High Way Lalad Sopore, maintaining at their own level. The said school building is situated out site limits of Municipal Council Sopore.

No: MC/Spr/G/20/7305-06

Dated: 05/02/2020


Executive Officer
Municipal Council
Sopore

Copy to the:-

01) Principal Sanctorum Higher Secondary School National Highway Lalad Sopore for information. This is with reference to his representation No: - of Dated: -04-02-2020.

02) File

